

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50181811

Blatt Page
0001

Ihr Zeichen Client Reference
H.X.F.


Unser Zeichen Our Reference
01-ZWC- 15037857 001

Ausstellungsdatum Date of Issue
10.06.2010 (day/mo/yr)

Genehmigungsinhaber License Holder
Zhejiang Kedu Electric
Manufacturing Co., Ltd.
Puqi Industrial Zone C
Hongqiao Town, Yueqing
Zhejiang 325608
P.R. China

Fertigungsstätte Manufacturing Plant
Zhejiang Kedu Electric
Manufacturing Co., Ltd.
Puqi Industrial Zone C
Hongqiao Town, Yueqing
Zhejiang 325608
P.R. China

Prüfzeichen Test Mark



Geprüft nach Tested acc. to
EN 60947-1:2007
EN 60947-3:1999+A1+A2
EN 60947-5-1:2004

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Schalter (Electromagnetic switch)

Type Designation	: KOA7 KOA8 KOA9 KOAab	8
	a=1 or 2	1
	b=M, L, Y or T	1

Ambient Temperature Limit: -5°C to 40°C

Rated Operational Voltage: 230V AC; 50/60Hz 400V AC; 50/60Hz

Rated Operational Current: 16A(AC-3) 12A(AC-3)
8A(AC-15)

Coventional Free Air

Thermal Current : 16A

Conditional Short-circuit

Current : 1000A

Pollution Degree : 3

Degree of Protection : IP54

The labelling requirements acc. to EU Directive 2001/95
have to be observed for distribution within the EEA.



10

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle

Dipl.-Ing. Matthias Grzam